

Radon Testing Results

Radon Levels Must below 4.0 pCi/L

All sites tested were all below recommended levels

Room Id	pCi/L	Test Date
E1	0.30	02/22/2019
E2	0.30	02/22/2019
E3	0.30	02/22/2019
E3	0.30	02/22/2019
E4	0.30	02/22/2019
E5	0.30	02/22/2019
E6	0.30	02/22/2019
E7 Class	0.30	02/22/2019
E7 Office	0.30	02/22/2019
E8	0.30	02/22/2019
GYM	0.30	02/22/2019
GYM	0.30	02/22/2019
GYM	0.30	02/22/2019
GYM	0.30	02/22/2019
GYM CUSTODIAL	0.30	02/22/2019
GYM STORAGE	0.30	02/22/2019
MAIN OFFICE	0.30	02/22/2019
PRINCIPAL	0.30	02/22/2019
RBC OFFICE	0.30	02/22/2019
STAFF	0.30	02/22/2019
STAFFRM	0.30	02/22/2019
BOILER RM	1.30	02/22/2019
CAFETERIA	0.30	02/22/2019
CAFETERIA	0.30	02/22/2019
CAFETERIA	0.80	02/22/2019
CAFETERIA OFF	1.20	02/22/2019
COMP LAB 1	0.30	02/22/2019
COMP LAB 2	0.90	02/22/2019
CUST. STORAGE	0.30	02/22/2019
GYM	0.30	02/22/2019
GYM	0.30	02/22/2019
GYM	0.30	02/22/2019
GYM	0.30	02/22/2019
GYM STORAGE	1.00	02/22/2019
HI	1.50	02/22/2019
H2	1.10	02/22/2019
H3	0.30	02/22/2019
H3	0.30	02/22/2019
H4	0.30	02/22/2019

Radon Testing Results

pg 2

Radon levels must be below 4.0 pCi/L

All sites tested were all below recommended levels

Room Id	pCi/L	Test Date
H4	0.30	02/22/2019
H5	1.40	02/22/2019
H6	0.80	02/22/2019
H7	0.30	02/22/2019
IT OFFICE	0.30	02/22/2019
MUSIC OFFICE	1.00	02/22/2019
MUSIC RM	0.30	02/22/2019
MUSIC STOR	0.90	02/22/2019
PE BOYS OFF	1.00	02/22/2019
CLASSROOM	1.40	02/22/2019
OFFICE	1.30	02/22/2019
SHOP	0.90	02/22/2019
SHOP	1.50	02/22/2019
SHOP	0.30	02/22/2019
SHOP	1.40	02/22/2019
EXAM RM1	1.10	02/22/2019
EXAM R JVI 2	1.30	02/22/2019
LAB	1.20	02/22/2019
LAB	0.30	02/22/2019
OFFICE	1.40	02/22/2019
RECEPTION	1.30	02/22/2019
RECEPTION	1.20	02/22/2019
STORAGE	1.10	02/22/2019
WAITING RM	1.20	02/22/2019
BD RM	0.30	02/22/2019
BD RM	2.90	02/22/2019
BD RM	2.60	02/22/2019
BDRM	1.40	02/22/2019
BDRM	2.70	02/22/2019
L1VRM	2.40	02/22/2019
SEWINORM	2.60	02/22/2019